

## Salgsliste transformatorer

Fabrikat	KVA	Fabrikk	abrik	Primær	Sekundær	Kopl grp.	Høysp
		Nummer	ÅR	Volt	Volt		Gjn.føring
Møre	31,5	860308	1986	22000+-2*2,5%	240	Yyn0	poselen
Møre	31,5	851230	1985	22000+-2*2,5%	240	Yyn0	poselen
ABB	200	420-40038-1	1994	10500 +-2x2,5%	415	Dyn11	elastimold
Møre	315	820858	1982	22000\11000 +-2x2,5%	240	Yyn0	poselen
NI	315	612-02563	1979	10000 +-2x2,5%	240	Yyn0	KP
NI	315	420-22019	1988	10500 +-2x2,5%	240	Yyn0	elastimold
NI	315	420-15689	1985	10500 +-2x2,5%	240	Yyn0	poselen
NI	315	420-16082	1985	21000\11000 +-2x2,5%	240	Yyn0	poselen
Møre	315	800015	1980	11000\5500 +-2x2,5%	240	Yyn0	poselen
ABB	315	420-43762	1999	22000\18000 +-2x2,5%	240\400	Dyn11\Dd0	elastimold
Møre	315	771240	1977	11000\5500 +-2x2,5%	240	Yyn0	elastimold
Møre	315	401511	2003	22000 / 11000 - 6*2%	415	Dyn11	poselen
Møre	315	810641	1981	11000\5200 +-2x2,5%	240	Yyn0	poselen
NI	315	420-21102	1987	10000 +-2x2,5%	240	Yyn0	elastimold
NI	300	66358	1975	10000 +-2x2,5%	400	Dyn11	elastimold
NI	315	012-	1980	10000 +-2x2,5%	237	Yyn0	poselen
Strømberg	500	5148440	1982	21000 +-2x2,5%	400	Dyn11	
Møre	500	821324	1982	22000 +-2x2,5%	240	Yyn0	poselen
Asea	500	83106-5	1983	10000 +-2x2,5%	240	Yyn0	poselen
Møre	500	801490	1980	10000 +-2x2,5%	240	Yyn0	KP
NI	630	410-05472	1984	10000 +-2x2,5%	240	Yyn0	poselen
NI	630	410-05471	1984	10000 +-2x2,5%	240	Yyn0	poselen
Møre	800	811486	1981	22000 +-2x2,5%	11 000	Yyn0	poselen
Møre	800	T961943	1996	18000 +-2x2,5%	400\230	Dyn11\Yn11	elastimold
ABB	800	420-42099	1996	11000 +2x2,5-4x2,5%	414\240	Dyn11\Dd0	elastimold
NI	800	410-03953	1982	10000 +-2x2,5%	400\230	Dyn11\Dd0	poselen
EB	800	410-06107	1985	21000 +-2x2,5%	660	Yd11	poselen
NI	800	410-03076	1981	10000 +-2x2,5%	230	Yyn0	KP
NI	800	012-02655	1981	22000\16500 +-2x2,5%	240	Yyn0	poselen
NI	800	012-02654	1981	22000\16500 +-2x2,5%	240	Yyn0	poselen
Pauwels	1000	8611432	1986	10 000+-2x2,5%	400\240	Dyn11\Dd0	elastimold
NI	1000	012-01072	1979	10000+-2x2,5%	240	Yyn0	poselen
Møre	1000	830438	1983	380	230	Yyn0	poselen
NI	1000	410-05628	1984	10000 +-2x2,5%	400\230	Dyn11\Dd0	poselen
EB	1000	410-09240	1989	10000 +-2x2,5%	240	Yyn0	elastimold
ABB	1250	229421	1990	6300 +-2x2,5%	400	Dyn11	elastimold
Møre	1250	851253	1985	22000+-2*2,5%	10000	Yyn0	
Møre	1250	851252	1985	22000+-2*2,5%	10000	Yyn0	
Møre	1600	890935	1989	22000+2-4*2,5%	10000	Yy0	
Møre	1600	890933	1989	22000+2-4*2,5%	10000	Yy0	
ABB	1600	420-44281	2000	11000 +2x2,5-4x2,5%	240	Yyn0	elastimold

ABB	200,600, 800	230878	1994	10000 +-2x2,5%	414\240	Dyn11	elastimold
Møre	315,315, 630	301615	2003	10000 +-2x2,5%	415\240	Dyn11\Yn11	elastimold